

## UK Declaration of Conformity Pressure Equipment (Safety) Regulations 2016

Document No.: 923-2890 Rev.: A 24/264

We declare under our sole responsibility that the products:

Type: **B1S, B2S, B1T, B2T, B1X, B2X, B1k, B2k, B3H.**

Description: **Bourdon type pressure switches**

as Pressure Accessory have been verified for the design criteria:

- Maximum allowable pressure for all pressure ranges: up to 1000 bar
- Internal Volume < 0,1 L
- Diameter of process connection < 20 mm bore.

We declare for all Group 1 and 2 Fluids, and pressure up to 1000 bar:

Category I, with module A, and **UK  
CA** marking


Category I does not mean that the product is less safe and it can, depending on application, still be installed in systems with Category III, for example.

Barksdale Controls Products GmbH Germany has a proven quality management system according to ISO 9001:2015 certified and monitored by TÜV Hessen Germany.

Year of **UK  
CA** marking: 2022

Barksdale GmbH, Reichelsheim, 24.10.2024

Michael Weileder



Managing Director

Tobias Diehl



Engineering Manager