

# TYPE APPROVAL CERTIFICATE

Certificate no.:  
**TAA00002WS**  
Revision No:  
**2**

## This is to certify:

that the Level Indicator

with type designation(s)  
**BNA-S21-S/-S22-S/-S31-S/-S32-S/-35-S/-36-S/-S41-S/-S42-S, BNA-SU102-S, L1-6bar, L2-10bar, L3-16bar, L4-16bar, L5-40bar, XM, XT, XMi, XTi (Ex), GK01, GK03**

issued to

**Barksdale GmbH**  
**Reichelsheim (Wetterau), Hessen, Germany**

is found to comply with

**DNV rules for classification – Ships, offshore units, and high speed and light craft**

## Application:

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.**

## Location classes:

Temperature	B
Humidity	B
Vibration	A
EMC	B
Enclosure	B

Issued at **Hamburg** on **2025-11-20**

This Certificate is valid until **2030-11-12**.

DNV local unit: **Augsburg**

Approval Engineer: **Holger Jansen**



for DNV

Digitally signed by: Dariusz Lesniewski  
Location: DNV SE, Germany

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.  
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

## Product description

### MAGNETIC ROTOR and accessories

BNA-S21-S/-S22-S: PN 25 / 300 lbs; L1 – 6bar, L2 – 10bar, L3 – 16bar

BNA-S31-S/-S32-S: PN 16 / 150 lbs; L4 – 16bar

BNA-S35-S/-S36-S: PN 16 / 150 lbs L4 – 16bar

BNA-S41-S/-S42-S: PN 40 / 600 lbs; L5 – 40bar

BNA-SU102-S: PN 16 / 150 lbs

Measuring scale with macrolon, aluminium or stainless steel indication rail

Measurement transducer (optional): any suitable type approved device

Indicator (optional): XM, XT

XMi, XTi Ex-Version

Option "Ex" for BNA, Option "EXI" for GK03

Option "S" marine approval for L1 to L5,

Option "A" Ex h approval for L1 to L5,

Option "B" marine and Ex h approval for L1 to L5

Limit switch GK01(03): 230 V AC, 0.8A, 60 VA

220 V DC, 0.8 A, 40 W

Degree of protection: IP 67(65)

In heavy fuel oil systems additional heating is recommend

## Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Ex-certification is not covered by this certificate. Application in hazardous area to be approved in each case according to the Rules and Ex-Certification/ Special Condition for Safe Use listed in valid Ex-certificate issued by a notified/recognized Certification Body.

## Type Approval documentation

Test Report: RMS No. 4-11 / 95

Pressure test: TÜV 6 from 09.01.1996

Data sheets: 923-1275; 923-1836; 923-2980; Levelsite Catalogue 923-2980 Index A

Cross reference-BNA-new order code

Catalogue: Barksdale Bypass Level Indicators, Index 923-0870 (edition 2013); Levelsite Catalogue 923-2980 Index A

Certificates: TÜV 08 ATEX 554726 X

Type approval assessment report issued at Augsburg on 2025-10-09

## Tests carried out

Applicable tests according to class guideline DNV-CG-0339, August 2021

## Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

## Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE