



B1S / B2S / B1T / B2T / D1S / D2S / D1H / D2H / D1T / D2T / DPD1T / DPD2T

The company named below has been authorized by Canadian Standards Association to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark -  - to these products according to the terms and conditions of the CSA Service Agreement.

NUMBR 022355X0000 September 1, 1993(Replaces:August 31, 1992)

CLASS 3231 02 (Re-examination Service)

IMO INDUSTRIES INC.

22355

Barksdale Controls Div.  
 3211 Fruitland Ave.  
 P.O. Box 58843  
 Los Angeles, CA 90058-0843  
 FACTORIES

F1 BARKSDALE CONTROLS DIV.  
 3211 Fruitland Ave.  
 P.O. Box 58843  
 Los Angeles, CA 90058-0843

F2 IMO INDUSTRIES GMBH  
 Div. Barksdale/Gems  
 Dorn-Assenheimer Strasse 27  
 6361 Reichelsheim 4 (Weckesheim), Germany

SWITCHES - Automatic - Pressure Type

- Bourdon tube operated switches - Model Nos B1S and B2S stripped models, Model Nos B1T and B2T weatherproof and watertight enclosure followed by A, B, C, E, F, H, J, K, M, X and GH followed by 12 through 120, may be followed by SS, and/or F1 through F10, and/or P1 through P10, and/or Q1 through Q99 and Suffix CS.

- Diaphragm operated switches - Model Nos D1S and D2S stripped models, Model No D1H and D2H general purpose enclosure with free leads, Model Nos D1T, D2T, DPD1T and DPD2T general purpose enclosure with terminal block followed by A, B, C, E, F, H, J, K, M, X or GH followed by 3 through 500, may be followed by SS and/or F1 through F10, and/or P1 through P10, and/or L1 through L20, and/or Q1 through Q99 followed by Suffix CS.

Note: Suffix letters A, B, C, E, F, H, J, K, M, X and GH denote different switches with ratings as follows (reduced ratings may be used):

A, H, J	10A at 125 and 250V ac
	3A at 300V ac
B, C, E, F, K	10A at 125, 250 and 300V ac
	.5A at 125V dc
	.25A at 250V dc

...cont'd